

Facility Summary in HILL County in the City of HAVRE

Location: ZIP TRIP 48
911 11TH ST W
HAVRE, MT 59501 HILL
Contact: Rick Bates, (509) 535-7701

Sys Fac ID: 21-00089
Last Inspected On: 4/8/2015
Operating Permit Renewal Date: 6/27/2018

Owners/Operators: CHS Inc - Spokane Valley, Owner	(509)-535-7701	16124 E MARIETTA LANE SPOKANE VALLEY WA 99216
Cenex Zip Trip, Operator	(509)-535-7701	16124 E MARIETTA LANE SPOKANE VALLEY WA 99216
Sean Hurley, UST Class A Operator		
Tom Savas, UST Class A Operator		
Luci Tuttle, UST Class B Operator		

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
3	04	10/1/2011	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
5341			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	
15,000			Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	Yes
4	04	10/1/2011	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
5342			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	
10,000			Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	Yes
5	04	10/1/2011	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
5343			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	
6,000			Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	Yes

Facility Summary in HILL County in the City of HAVRE

Location: ZIP TRIP 49
1004 1ST ST
HAVRE, MT 59501 HILL
Contact: (406) 265-9812

Sys Fac ID: 21-00103
Last Inspected On: 10/18/2013
Operating Permit Renewal Date: 12/4/2016

Owners/Operators: CHS Inc - Spokane Valley, Owner (509)-535-7701 16124 E MARIETTA LANE
SPOKANE VALLEY WA 99216
Cenex Zip Trip, Operator (509)-535-7701 16124 E MARIETTA LANE
SPOKANE VALLEY WA 99216
Tom Savas, UST Class A Operator
Luci Tuttle, UST Class B Operator
Alex Henson, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
4	02	5/1/2013	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
5405		5/1/2013	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
12,000				Not Listed	Yes
5	02	5/1/2013	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
5406		5/1/2013	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
6,000				Not Listed	Yes
6	02	5/1/2013	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
5407		5/1/2013	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
4,000				Not Listed	Yes

Facility Summary in HILL County in the City of HAVRE

Location: STROMBERGS SINCLAIR

1200 1ST ST

HAVRE, MT 59501 HILL

Contact: Howard Stromberg, (406) 265-3441

Sys Fac ID: 21-02166

Last Inspected On: 8/28/2013

Operating Permit Renewal Date: 12/13/2016

Owners/Operators: Stromberg Enterprises Inc, Owner

(406)-265-2824

PO BOX 608

HAVRE MT 59501-0608

Howard O Stromberg, UST Class A Operator

Howard O Stromberg, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
8	16	3/1/1999	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
3965			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
12,000					
9	16	3/1/1999	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
3966			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
8,000					
10	16	3/1/1999	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
3967			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
4,000					

Facility Summary in HILL County in the City of HAVRE

Location: EZZIES CENEX CARDTROL
5 1ST ST
HAVRE, MT 59501 HILL
Contact: Larry Poulton, (406) 265-7636

Sys Fac ID: 21-07467
Last Inspected On: 9/5/2014
Operating Permit Renewal Date: 1/7/2018

Owners/Operators: EZZIES WHOLESALE INC, Owner (406)-654-2331 PO BOX 1770
MALTA MT 59538-9640
David Skiff, UST Class A Operator
Harold Anderson, UST Class B Operator
Jimmy Kimberling, UST Class B Operator
David Skiff, UST Class B Operator
David Skiff, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
8	18	6/1/1997	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
538			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
4,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
9	18	6/1/1997	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
539			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
4,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
10	18	6/1/1997	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
540			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
4,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
11	18	6/28/1997	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
541			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
6,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in HILL County in the City of HAVRE

Location: EZZIES CENEX CARDTROL
5 1ST ST
HAVRE, MT 59501 HILL
Contact: Larry Poulton, (406) 265-7636

Sys Fac ID: 21-07467
Last Inspected On: 9/5/2014
Operating Permit Renewal Date: 1/7/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
12	18	6/28/1997	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
542			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
6,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
13	18	6/1/1997	Fiberglass Reinforced Plastic	Flexible Plastic	High Level Alarm
543			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
8,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in HILL County in the City of HAVRE

Location: HOLIDAY STATIONSTORE 272
200 1ST ST W
HAVRE, MT 59501 HILL

Contact: (406) 265-8421

Sys Fac ID: 21-08068

Last Inspected On: 9/4/2014

Operating Permit Renewal Date: 12/4/2017

Owners/Operators: Rocky Mountain Oil Co Inc, Owner

(952)-830-8899

ATTN: ENVIRONMENTAL DIRECTOR
PO BOX 1224
MINNEAPOLIS MN 55437-1123

Stephen Reckinger, UST Class A Operator
Dean Townsend, UST Class A Operator
Ronald VanDenBroeke, UST Class A Operator
Todd Boucher, UST Class B Operator
Stephen Reckinger, UST Class B Global Operator
Travis Struckman, UST Class B Global Operator
Dean Townsend, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	30	10/1/1985	Cathodically Protected Steel	Steel	Ball Float Valve
3013			Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		9/4/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	Yes
12,000		7/8/2014	TLS-350/Gilbarco EMC , Veeder Root	Automatic Tank Gauging 0.1	
2	30	10/1/1985	Cathodically Protected Steel	Steel	Ball Float Valve
3014			Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		9/4/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	Yes
12,000		2/28/2014	TLS-350/Gilbarco EMC , Veeder Root	Automatic Tank Gauging 0.1	
3	30	10/1/1985	Cathodically Protected Steel	Steel	Ball Float Valve
3015			Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		9/4/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	Yes
10,000		2/26/2014	TLS-350/Gilbarco EMC , Veeder Root	Automatic Tank Gauging 0.1	

Facility Summary in HILL County in the City of HAVRE

Location: HOLIDAY STATIONSTORE 272
200 1ST ST W
HAVRE, MT 59501 HILL
Contact: (406) 265-8421

Sys Fac ID: 21-08068
Last Inspected On: 9/4/2014
Operating Permit Renewal Date: 12/4/2017

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
4	30	10/1/1985	Cathodically Protected Steel	Steel	Ball Float Valve
3016			Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		9/4/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
10,000		3/2/2014	TLS-350/Gilbarco EMC , Veeder Root	Automatic Tank Gauging 0.1	

Facility Summary in HILL County in the City of HAVRE

Location: TOWN PUMP INC HAVRE
136 1ST ST W
HAVRE, MT 59501 HILL

Sys Fac ID: 21-08705

Last Inspected On: 12/28/2015

Operating Permit Renewal Date: 4/1/2019

Contact: Trent Biggers, (406) 497-6700

Owners/Operators: Town Pump of Havre Inc, Owner (406)-497-6700 PO BOX 6000
BUTTE MT 59702-6000

Charles A Armstrong, UST Class A Operator
Trent Biggers, UST Class A Operator
Don Edmisten, UST Class A Operator
Daniel Sampson, UST Class A Operator
Charles A Armstrong, UST Class B Global Operator
Trent Biggers, UST Class B Global Operator
Don Edmisten, UST Class B Global Operator
Daniel Sampson, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
3	26	11/15/1989	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2472		2/4/2015	None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
12,000		1/29/2015	TLS-350/Gilbarco EMC , Veeder Root		
4	26	11/15/1989	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2473		2/4/2015	None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
12,000		1/29/2015	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in HILL County in the City of HAVRE

Location: TOWN PUMP INC HAVRE
136 1ST ST W
HAVRE, MT 59501 HILL
Contact: Trent Biggers, (406) 497-6700

Sys Fac ID: 21-08705
Last Inspected On: 12/28/2015
Operating Permit Renewal Date: 4/1/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
5	26	11/15/1989	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2474		2/4/2015	None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
12,000		1/29/2015	TLS-350/Gilbarco EMC , Veeder Root		
6	26	11/15/1989	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2475		2/4/2015	None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
12,000		1/29/2015	TLS-350/Gilbarco EMC , Veeder Root		
7	01	8/1/2014	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
5510		2/4/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
6,000		1/29/2015	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor, Not Listed	
8	01	8/1/2014	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff), High Level Alarm
5514		2/4/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
15,000		1/29/2015	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor, Not Listed	

Facility Summary in HILL County in the City of HAVRE

Location: BN HAVRE WWTP
235 MAIN ST
HAVRE, MT 59501 HILL

Sys Fac ID: 21-09548

Last Inspected On: 6/17/2014

Operating Permit Renewal Date: 8/26/2017

Contact: Harry Rencurel, (406) 265-0483

Owners/Operators: BNSF Railway Havre, Owner (406)-265-0483 235 MAIN ST
HAVRE MT 59501-3523

Michael J Perrodin, UST Class A Operator
Ed Hill, UST Class B Operator
Michael J Perrodin, UST Class B Operator
Tom Swinney, UST Class B Operator
Dwayne Whitaker, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
6	22	6/21/1993	Cathodically Protected Steel	No Piping	High Level Alarm
506			Double-Walled	None	Yes
Currently in Use			Not Required	Not Listed	Impressed Current
Waste Oil		3/28/2014	Manual Interstitial Monitor	Deferred	
20,000					
17	12	1/22/2004	Concrete	Steel - Terminal Piping	
4877	Yes		None	none	Yes
Currently in Use			Not Required	Pressurized	Not Applicable, Impressed Current
Diesel		3/28/2014	Deferred	MLLD Line Tightness Testing, ELLD Line Tightness Testing	
640,000		9/30/2014	LDE Series , Pneumercator	Continuous Interstitial Monitor	
18	12	1/22/2004	Concrete	Steel - Terminal Piping	
4878	Yes		None	none	Yes
Currently in Use			Not Required	Pressurized	Not Applicable, Impressed Current
Diesel		3/28/2014	Deferred	MLLD Line Tightness Testing, ELLD Line Tightness Testing	
640,000		9/30/2014	LDE Series , Pneumercator	Continuous Interstitial Monitor	

Facility Summary in HILL County in the City of HAVRE

Location: EZZIES WHOLESALE HAVRE
726 1ST ST W
HAVRE, MT 59501 HILL

Sys Fac ID: 21-12751

Last Inspected On: 3/20/2013

Operating Permit Renewal Date: 7/9/2016

Contact: Lawrence Poulton, (406) 265-7636

Owners/Operators: EZZIES WHOLESALE INC, Owner

(406)-654-2331

PO BOX 1770
MALTA MT 59538-9640

David Skiff, UST Class A Operator

Harold Anderson, UST Class B Operator

Jimmy Kimberling, UST Class B Operator

David Skiff, UST Class B Operator

David Skiff, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	23	7/1/1992	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
883			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		3/20/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
12,000		8/29/2007			
2	23	7/1/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
884			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		3/20/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
12,000		8/29/2007			
3	23	7/1/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
882			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		3/20/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
12,000		8/29/2007			
4	23	7/1/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
885			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		3/20/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
12,000		8/29/2007			

Facility Summary in HILL County in the City of HAVRE

Location: EZZIES WHOLESALE HAVRE
726 1ST ST W
HAVRE, MT 59501 HILL

Contact: Lawrence Poulton, (406) 265-7636

Sys Fac ID: 21-12751
Last Inspected On: 3/20/2013
Operating Permit Renewal Date: 7/9/2016

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
5	23	7/1/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
878			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Solvents		3/20/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	
4,000		3/21/2013			
6	23	7/1/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
879			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		3/20/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
12,000		8/29/2007			
7	23	7/1/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
880			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		3/20/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
12,000		8/29/2007			
8	23	7/1/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
881			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		3/20/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
12,000		8/29/2007			

Facility Summary in HILL County in the City of HAVRE

Location: EMPORIUM FOOD & FUEL
1415 1ST ST
HAVRE, MT 59501 HILL
Contact: Bill Dritshulas, (406) 265-8861

Sys Fac ID: 21-12763
Last Inspected On: 3/20/2013
Operating Permit Renewal Date: 6/30/2016

Owners/Operators: William Dritshulas, Owner (406)-265-8861 PO BOX 1430
HAVRE MT 59501-1430
MATTHEW BAUER, UST Class A Operator
Jonathan Wells, UST Class A Operator
Ilias Dimou, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	23	8/1/1992	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
2971			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	
12,000					
2	23	8/1/1992	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
2972			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	
12,000					
3	23	8/1/1992	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
2973			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	
6,000					
4	23	8/1/1992	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
2974			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	
6,000					

Facility Summary in HILL County in the City of HAVRE

Location: HILL COUNTY JUSTICE CENTER
1450 2ND ST W
HAVRE, MT 59501 HILL

Sys Fac ID: 56-13886

Last Inspected On: 4/3/2013

Operating Permit Renewal Date: 4/30/2016

Contact: Kathy Bessette, (406) 265-5481

Owners/Operators: Hill County Commissioners, Owner (406)-265-5481 315 4TH ST
HAVRE MT 59501-3923

Daryl Anez, UST Class A Operator
Richard Ricci, UST Class A Operator
Daryl Anez, UST Class B Operator
Daryl Anez, UST Class B Global Operator
Richard Ricci, UST Class B Global Operator
Mike Winchell, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	17	7/20/1998	Concrete	Steel	High Level Alarm
1377	Yes		None	Secondary Containment Chase	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Deferred	Not Listed	
2,000					

Facility Summary in HILL County in the City of HINGHAM

Location: HINGHAM MOTORS
CENTRAL AVE & 1ST ST N
HINGHAM, MT 59528 HILL

Sys Fac ID: 21-00783

Last Inspected On: 4/9/2014

Operating Permit Renewal Date: 5/14/2017

Contact: Gary Sudan, (406) 397-3215

Owners/Operators: Hingham Motors, Owner

(406)-397-3215

PO BOX 226
HINGHAM MT 59528-0228

Gary Sudan, Operator

(406)-397-3215

297 ROAD 155 N
HINGHAM MT 59528

Robert Spicher, UST Class A Operator

Robert Spicher, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
4	20	7/25/1995	Unknown	Flexible Plastic	
1383	Yes	5/13/2014	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Deferred	Continuous Interstitial Monitor	
12,000			TLS-350/Gilbarco EMC , Veeder Root		
7	17	10/1/1998	Unknown	Flexible Plastic	
1384	Yes	5/13/2014	None	Double-Walled	Yes
Currently in Use		1/1/2008	Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Deferred	Continuous Interstitial Monitor	
12,000			Other , Other		
8	17	10/1/1998	Unknown	Flexible Plastic	
1385	Yes	5/13/2014	None	Double-Walled	Yes
Currently in Use		1/1/2008	Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Deferred	Continuous Interstitial Monitor	
12,000			Other , Other		
9	17	10/1/1998	Unknown	Flexible Plastic	
1386	Yes	5/13/2014	None	Double-Walled	Yes
Currently in Use		1/1/2008	Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Deferred	Continuous Interstitial Monitor	
12,000			Other , Other		

Facility Summary in HILL County in the City of INVERNESS

Location: FRASER OIL INC INVERNESS
US HIGHWAY 2
INVERNESS, MT 59530 HILL
Contact: Duane Fraser, (406) 292-3833

Sys Fac ID: 21-07327
Last Inspected On: 12/11/2014
Operating Permit Renewal Date: 3/27/2018

Owners/Operators: Fraser Oil Inc, Owner (406)-292-3833 PO BOX 770
INVERNESS MT 59530-0770
Cory Fraser, UST Class A Operator
Cory Fraser, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
4	23	10/15/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
1120			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		12/11/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Deferred	
1,000		12/11/2008	Gilbarco EMC Basic , Gilbarco		
5	23	10/15/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
1121			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		12/11/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Deferred	
1,000		12/11/2008	Gilbarco EMC Basic , Gilbarco		
6	23	10/15/1992	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
1122			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		12/11/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Deferred	
1,000		12/11/2008	Gilbarco EMC Basic , Gilbarco		

Facility Summary in HILL County in the City of RUDYARD

Location: TONERS TIRE RAMA
103 MAIN ST
RUDYARD, MT 59540 HILL

Sys Fac ID: 21-02475

Last Inspected On: 8/6/2013

Operating Permit Renewal Date: 9/24/2016

Contact: Robert Toner, (406) 355-4131

Owners/Operators: Toners Tire Rama, Owner (406)-355-4131 PO BOX 266
RUDYARD MT 59540-0266

Rick Pester, UST Class A Operator

David Toner, UST Class A Operator

Rick Pester, UST Class B Operator

David Toner, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
5	18	11/1/1997	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
2108			None	None	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Diesel		8/6/2013	Automatic Tank Gauging 0.2	Deferred	
2,000					
6	18	11/1/1997	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	High Level Alarm
2109			None	None	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Gasoline		8/6/2013	Automatic Tank Gauging 0.2	Deferred	
2,000					

Facility Summary in HILL County in the City of RUDYARD

Location: FARMERS UNION OIL CO RUDYARD
1 MAIN ST PO BOX C
RUDYARD, MT 59540 HILL

Sys Fac ID: 21-03509

Last Inspected On: 7/18/2013

Operating Permit Renewal Date: 9/28/2016

Contact: William Gorder, (406) 355-4543

Owners/Operators: Farmers Union Oil Co Rudyard, Owner

(406)-355-4543

PO BOX 290

RUDYARD MT 59540-0290

Larry Horinek, UST Class A Operator

Larry Horinek, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
4	49	4/23/1966	Bare Steel	Fiberglass Reinforced Plastic	
947	Yes	12/26/2012	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Deferred	Continuous Interstitial Monitor	
2,000					
5	49	4/23/1966	Bare Steel	Fiberglass Reinforced Plastic	
948	Yes	12/26/2012	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Deferred	Continuous Interstitial Monitor	
10,000					
6	49	4/23/1966	Bare Steel	Fiberglass Reinforced Plastic	
949	Yes	12/26/2012	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Deferred	Continuous Interstitial Monitor	
5,000					